HIDE-A-WAY LAKE CLUB, INC.

P.O. Box 1011
PICAYUNE, MISSISSIPPI 39466-1011

Phone: 601-798-1484 **Fax: 601-798-0604**
Web address: www.hawlms.com **Email address: office@hawlms.net**

TO: HIDE-A-WAY LAKE WATER SYSTEM CUSTOMERS

FROM: HIDE-A-WAY LAKE WATER SYSTEM PWSID# 0550013

DATE: OCTOBER 26, 2026

IMPORTANT INFORMATION ON WATER SYSTEM MONITORING REQUIREMENT, WHICH WAS NOT MET FOR SEPTEMBER 2026

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During September 2026, we did not complete all monitoring or testing for CHLORINE and therefore cannot be sure of the quality of our drinking water during that time.

Our water system requires three monthly water test samples to be sent to the Mississippi State Department of Health Laboratory.

In September 2026, Hide-A-Way Lake Water System performed three samples, all of which showed good results; however, on one sample form we omitted to log the field chlorine residual on the sample form which is deemed a *monitoring violation.* **However, chlorine was tested and was within normal range, just not logged on the form.** Our water system chlorine residuals are between 1.20 – 2.0 milligrams per liter. Even though this was not considered an emergency, as our customer you have the right to be informed.

The Hide-A-Way Lake Water System will return to compliance on January 1, 2027.

For more information, please contact Hide-A-Way Lake Water System operator Bryan Blackwell or General Manager Bruce Devillier at 601-798-1484, P.O. Box 1011 Picayune, MS 39466, or at office@hawlms.net.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly. You can do this by posting this notice in a public place or distributing copies by hand or mail.